

June 25, 2018

To: All Bidders - Town of Yucca Valley Request for:
**PAVEMENT REHABILITATION
YUCCA MESA ROAD/LA CONTENTA ROAD
TOWN PROJECT NO. 7003**

From: Noel Owsley, Town Engineer

Subject: Request For Information (RFI) No. 1

Question 1:

I am trying to locate the Size Aggregate to be used for the above mentioned project for the Double Chip Seal.

Would the first course chip seal be 1/2" and then followed by a 3/8"?

Response:

We will be going with the 3/8" for the base. It would be Medium for the base and Medium Fine for the surface course per Table 200-1.2.2.2 of the Greenbook.

TOWN OF YUCCA VALLEY
ENGINEERING DIVISION

Noel Owsley
Town Engineer